

LOCATION 935 S Chestnut CITY Gastonia
 BETWEEN 9th STREET & Lead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>D</u>	<u>91</u>		<u>9</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>D</u>	<u>40</u>		<u>4-21-99</u>	
PROP. LINE TO BLDG	<u>3/4</u>	<u>D</u>	<u>51</u>			

ENTERS: 935 BRANCHED INTO: 0
 TAP SIZE: 1/8 PRESSURE _____ PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY EP
 MAIN SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1961
 DEPTH 2 FT 0 IN LOCATION _____

"A" P/S READING .85 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.51</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>0.51</u>

