

LOCATION 1006 S. Chestnut CITY Gastonia

BETWEEN 9th STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>D</u>	<u>101</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>D</u>	<u>30</u>			<u>4/21/99</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>D</u>	<u>71</u>			

ENTERS 1006 BRANCHED INTO 0

TAP SIZE 3/4 SM PRESSURE 600 PSI INCHES W C LOCATION

PRESSURE TEST 100 PSI FOR 114 HRS BY CP

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1961

DEPTH. 2 FT 0 IN LOCATION

"A" P/S READING .85 TOTAL ANODES 1# 1 17# 1 LR #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

