

LOCATION 1001 Cheviot Ln CITY Roseville
BETWEEN Heatherlock Dr. STREET & Arbroath Trace STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	104'	10-24-02		
MAIN TO PROP. LINE	5/8"	P	8'	"		
PROP LINE TO BLDG	5/8"	P	96'	"		

ENTERS 1001 BRANCHED INTO 0

TAP SIZE 1/2" PRESSURE 60 PSI INCHES W C LOCATION 222' East of

center of Heatherlock Dr.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY d. Woody

MAIN SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1973

DEPTH: 3' FT 0" IN LOCATION 15' south of center of Cheviot Ln.

"A"-P/S READING 1.12 TOTAL ANODES 1# 0 17# 0 I.R. # 315756

REMARKS: New Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	service