

LOCATION 318 Church St. CITY GASTONIA
BETWEEN Church St. STREET & Aberdeen Blvd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>52'</u>	<u>10-10-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>27'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>25'</u>			

ENTERS: 318

BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 70' E of Church St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Rh

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1962

DEPTH: 4 Ft. 0 In. LOCATION 5' S of E of East Sixth St.

"A" P/S READING 1.4 TOTAL ANODES 1* 17* L.R. # 504356

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY