

LOCATION 404 S. ChurchCITY GASTONIABETWEEN 3rdSTREET & Edwards

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>2'</u>	<u>4-9-94</u>	<u>Ticover</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>C+W</u>	<u>38' Existing C+W</u>			
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 132 South of Edwards


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION 18 E. of Church

"A" P/S READING 1.4 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Tracer wire Not Bonded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>B.R.</u>	<u>1.4</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY