

LOCATION 1016 S Church St CITY Catskill  
BETWEEN 10th STREET & 9th STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>d/w</u>	<u>39'</u>	<u>Replaced 8-21-98</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1016 BRANCHED INTO:  
TAP SIZE: 3/4 Ser. PRESSURE 600 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 200 PSI FOR 44 HRS. BY EP  
MAIN SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_  
DEPTH: 1 FT. 6 IN. LOCATION \_\_\_\_\_

"A" P/S READING 1.2 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>At Ser</u>	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY