


LOCATION 840 Churchill Dr.CITY GastoniaBETWEEN CarmenSTREET & Churchill

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>121</u>			<u>11-4-97</u>
MAIN TO PROP. LINE	<u>11</u>	<u>1</u>	<u>21'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>1</u>	<u>100'</u>			

ENTERS: 840BRANCHED INTO: 0TAP SIZE: 3/4PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.LOCATION 162' E of Cot  
ChurchillPRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION 9' S of c of Carmen"A" P/S READING Plastic TOTAL ANODES 1\* - 17\* - L.R. # -

REMARKS:



## Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>8 R.</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY