

LOCATION 944 Churchill Dr CITY Gastonia

BETWEEN Wilkins STREET & Carmen STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	110		11-	5-97
MAIN TO PROP. LINE	11	"	42			
PROP. LINE TO BLDG.	11	"	68			

ENTERS: 944 BRANCHED INTO: 0

TAP SIZE: 3/4 PRESSURE 60 PSI 1 INCHES W.C. LOCATION 83' N of c of church'll Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BC

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. IN. LOCATION 22' W of c of church'll

"A" P/S READING plastic TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY