

LOCATION 1402 Circle DrCITY GastoniaBETWEEN Oakdale DrSTREET & Beverly Dr

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>135'</u>	<u>11-16-94</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>37'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>98'</u>			

ENTERS: 1402BRANCHED INTO: —TAP SIZE: 1/2

PRESSURE

P.S.I.


INCHES W.C.

LOCATION 20' E. of C ofCircle Dr.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JPMAIN-SIZE 1" C.I. — BARE STEEL ✓ COATED STEEL — PLASTIC — YEAR INSTALLED 1954DEPTH: 2 Ft. 6 In.

LOCATION

"A" P/S READING .60TOTAL ANODES 1* 1 17* —L.R. # —

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	