

LOCATION 1406 CIRCLE DR.CITY GASTONIABETWEEN BEVERLYSTREET & OAKDALE

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PLASTIC</u>	<u>208'</u>		<u>6-26-97</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>168'</u>			

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION E. SIDE OF 1406PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY B.T.MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 97DEPTH: 4 FT. IN. LOCATION S. SIDE OF CIRCLE DR."A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY