


LOCATION 1410 CIRCLE DR CITY GASTONIABETWEEN BEVERLY STREET & OAKDALE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>137'</u>		<u>6-25</u>	<u>-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>97'</u>			

ENTERS: Same BRANCHED INTO:TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION W. side of 1410PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY BTMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 4 FT. IN. LOCATION S. side of CIRCLE DR"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY