

LOCATION 702 CHARA St.

CITY GastoniaBETWEEN Union RdSTREET & Dead End

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	2'	1-5-94	til over 47' 3/4 P. Sov.	
MAIN TO PROP. LINE					to End 2" P. Main	
PROP. LINE TO BLDG.						

ENTERS: 702

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

11' W. of C of
Clara St.

PRESSURE TEST: @ 100 psi

For 1/4 Hrs.

By

JP

MAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED 1992

DEPTH:

3

Ft.

0

In.

LOCATION


"A" P/S READING

P

TOTAL ANODES 1# 17#

L.R. #

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	P.
P/S Pipeline Lead - White Existing Main	E	