

LOCATION 333 Claudette Dr. CITY GASTONIA  
BETWEEN 321 South STREET & Lyon St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>100'</u>	<u>6-5-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>60'</u>			

ENTERS: 333

BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 600 PSI \_\_\_\_\_ INCHES W.C. LOCATION 171' E of C of Lyon St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1970

DEPTH: 3 FT. 0 IN. LOCATION 18' N of C of Claudette Dr.

"A" P/S READING .80 TOTAL ANODES 1# \_\_\_\_\_ 17# 1 L.R. # 406934

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

ENG. DEPT. USE ONLY