

LOCATION 400 Claudette Dr CITY Gastonia

BETWEEN Lyon St. STREET & Enma Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>58'</u>	<u>3-23-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>4'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>54'</u>	<u>"</u>		

ENTERS 400 Claudette Dr. BRANCHED INTO D

TAP SIZE 3/8" PRESSURE 60 PSI INCHES W C LOCATION 104' West of center of Lyon St.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.R.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1966

DEPTH 3' FT 0" IN LOCATION 16' north of center of Claudette Dr.

"A" P/S READING .8 TOTAL ANODES 1# 0 17# 1 LR # 00210307

REMARKS New 3/4" P. service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red	<u>S</u>	<u>plastic riser</u>
New Service		
P/S Pipeline Lead - White	<u>E</u>	
Existing Main		