

LOCATION 305 S. Clay StCITY GastoniaBETWEEN 2ndSTREET & 3rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>13' / 43' Existing</u>			<u>6-4-97</u>
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 305

BRANCHED INTO:

TAP SIZE: 3/4 stubPRESSURE 60

PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SEMAIN SIZE 3/4 stub

C.I. \_\_\_\_\_

BARE STEEL \_\_\_\_\_


COATED STEEL \_\_\_\_\_

PLASTIC ☒YEAR INSTALLED 9-5-91DEPTH: 2 FT. 0 IN.

LOCATION

"A" P/S READING PTOTAL ANODES 1# 1 17# \_\_\_\_\_

L.R. # \_\_\_\_\_

REMARKS: USED 43' OF EXISTING 3/4" PLASTIC. ALL AIR TESTED AT 100PSI FOR 15 min

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY