


LOCATION	501 S. Clay ST.			CITY	GASTONIA	
BETWEEN	HARRIS Ave		STREET &	FOURTH ST.		STREET
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	49'	2-2-95		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	44'			

ENTERS: 501		BRANCHED INTO:	
TAP SIZE: 1/2	PRESSURE 60 P.S.I.	INCHES W.C.	LOCATION 75' S. of center of Fourth ST.

PRESSURE TEST: @ 160 psi For 1/4 Hrs. By S. Huffstigh			
MAIN-SIZE 2"	C.I. —	BARE STEEL —	COATED STEEL — PLASTIC <input checked="" type="checkbox"/> YEAR INSTALLED 1991
DEPTH: 3 Ft.	In.	LOCATION 17' W. of center of S. Clay ST.	

"A" P/S READING 7	TOTAL ANODES 1# 0 17# 0	L.R. # 48231
-------------------	-------------------------	--------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY