

LOCATION 511 S. Clay St. CITY EASTONIA
BETWEEN 4th St. STREET & Harvie Ave. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>60'</u>	<u>10-14-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>12'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>48'</u>			

ENTERS: 511 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 27' S of Harvie Ave.

PRESSURE TEST: @ 100 psi For 14 Hrs. By RL
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1991
DEPTH: 3 Ft. 0 In. LOCATION 16' W of C of S. Clay St.

"A" P/S READING Plastic TOTAL ANODES 1* 17* L.R. # 452 534

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY