

LOCATION 503 + 503 1/2 Clinton DR CITY CRISTONIA
 BETWEEN Fairfield DR STREET & Fairfield DR STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Cxw Plastic	137' 5'	Tied over 6/4/94		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 503 + 503 1/2 BRANCHED INTO:
 TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION North side of 503 + 503 1/2

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DR
 MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1993
 DEPTH: 3 Ft. In. LOCATION West side of Clinton DR

"A" P/S READING .50 TOTAL ANODES 1# 17# L.R. #

REMARKS: Tied over 130' of 2x 3/4" Cxw Service to 503 1/2
Tied over 2' of 2x 3/4" " " " 503
2x 3/4" Fws jumped The .50 P.S. Reading was taken Before
1st Anode Installed



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>503</u> <u>R</u>	<u>1.0</u>
P/S Pipeline Lead - White Existing Main	<u>503 1/2</u> <u>R</u>	<u>1.10</u>

ENG. DEPT. USE ONLY