

LOCATION 506 Clinton Dr. CITY GASTONIA

BETWEEN Fairfield C.R. STREET & FAIRFIELD C.R. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	170'	10-27-95		
MAIN TO PROP. LINE	3/4"	P	30'			
PROP. LINE TO BLDG.	3/4"	P	140'			

ENTERS: 506 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 347' S. of center of Fairfield C.R.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFEL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 15' W. of center of Clinton Dr.

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # 550990

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY