

LOCATION 508 Clinton Dr. CITY GASTONIA  
BETWEEN FAIRFIELD DR STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>BARE</u>	<u>158'</u>		<u>6/11/94</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 508 BRANCHED INTO:  
TAP SIZE: PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION

PRESSURE TEST: @ \_\_\_\_\_ psi For \_\_\_\_\_ Hrs. By \_\_\_\_\_  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL ☒ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1949  
DEPTH: 2' Ft. 6 In. LOCATION

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Retired Service Purged  
With Air And Bare Main Replacement  
Capped With Main Program  
See INV# 088406 FOR Renewal of Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY