

LOCATION 508 Clinton Dr.CITY GASTONIABETWEEN Fairfield Dr.

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3 1/4"	Plastic	153			6/11/94
MAIN TO PROP. LINE	3 1/4"		45			
PROP. LINE TO BLDG.	3 1/4"		108			


ENTERS: 508

BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION South side of 508PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DTMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In. LOCATION South side of Fairfield Dr.

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY