


LOCATION 917 CloisterCITY GastoniaBETWEEN AugustaSTREET & Carnoustie

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	138'	1-24-94		
MAIN TO PROP. LINE	3/4	P	38'			
PROP. LINE TO BLDG.	3/4	P	100			

ENTERS: 917BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION W. Side of 917PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1989DEPTH: 3 Ft. _____ In. LOCATION 22' S of C of Cloister"A" P/S READING Plastic TOTAL ANODES 1* - 17* - L.R. # 15241

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY