


LOCATION 949 Cloister Dr. CITY GASTONIABETWEEN Carnegie Dr. STREET & Agusta Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>160'</u>	<u>11-21-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>140'</u>			

ENTERS: 949 BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W.C. LOCATION 250' E of Caf Carnegie Dr.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RLMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1990DEPTH: 3 FT. 0 IN. LOCATION 20' S of Caf Cloister Dr."A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 650 771

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY