

LOCATION 1105 Clouse StCITY GASTONIA

BETWEEN

HARGROVE

STREET &amp;

OAKWOOD

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>CW</u>	<u>3' RETURNED</u>		<u>2-24-95</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1105

BRANCHED INTO:

TAP SIZE: 3/4

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION 81' south ofClouse

PRESSURE TEST: @

100

psi

For

1/4

Hrs.

By

M. Parker

MAIN-SIZE

3/4

C.I.

BARE STEEL

COATED STEEL

X

PLASTIC

YEAR INSTALLED 1968

DEPTH:

1

Ft.

6

In.

LOCATION

144' W OF OAKWOOD ST.

"A" P/S READING


1.2

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY