

LOCATION 2933 Club Dr.CITY EASTONIABETWEEN Downey PlaceSTREET & Treasure Lane

STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|-------------|---------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>PLASTIC</u> | <u>105'</u> | <u>9-5-97</u> | | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>PLASTIC</u> | <u>14'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>PLASTIC</u> | <u>91'</u> | | | |

ENTERS: 2933BRANCHED INTO: 0TAP SIZE: 3/8PRESSURE 60 PSI

INCHES W.C.

LOCATION 430' E of C of Downey PlacePRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RLMAIN-SIZE 4" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1972DEPTH: FT. IN. LOCATION 15' S of C of Club Dr."A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # 592237

REMARKS:



| Test Station | | |
|--|----------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>Riser</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | <u>PLASTIC</u> |

ENG. DEPT. USE ONLY