

LOCATION 3023 Chb CITY Dartmouth
BETWEEN Treasure Lane STREET & Whitson Rd STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>99</u>	<u>1-13-54</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>10</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>89</u>			

ENTERS: 3623 BRANCHED INTO:
TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION W

PRESSURE TEST: @ 100 psi For 14 Hrs. By J. Bennett
MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1962
DEPTH: 2 Ft. 6 In. LOCATION 10' Depth

"A" P/S READING .70 TOTAL ANODES 1* 17 * 1 L.R. # 00007769

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY