

LOCATION 507 E. CLUB DR.

CITY GASTONIA

BETWEEN E. FRANKLIN BLVD.

STREET & —

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	PLASTIC	126	1-21-94		
MAIN TO PROP. LINE	3/4	"	42			
PROP. LINE TO BLDG.	3/4	"	84			

ENTERS: 507

BRANCHED INTO: —

TAP SIZE: 3/8

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

E. SIDE ST.

PRESSURE TEST: @ 100 psi

For 1 1/4 Hrs.

By

MAIN-SIZE 2"

C.I. —

BARE STEEL —

COATED STEEL ☒

PLASTIC —

YEAR INSTALLED 1967

DEPTH:

2

Ft.

6

In.

LOCATION

"A" P/S READING

.7


TOTAL ANODES 1# — 17# 1

L.R. #

23893

REMARKS: NO ANODE INSTALLED WAREHOUSE OUT

Installed 17# Anode



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	PLASTIC
P/S Pipeline Lead - White Existing Main	E	