

LOCATION 1721 Clubview Cir. CITY Gastonia  
BETWEEN Brentwood Dr. STREET & Country Club Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>75'</u>	<u>9-5-00</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>70'</u>			

ENTERS. — BRANCHED INTO —  
TAP SIZE: 3/4 PRESSURE 60 PSI — INCHES WC LOCATION 15' N. Country Club  
128' W. Clubview Cir.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY CR  
MAIN SIZE 2" C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1979  
DEPTH 3 FT 6 IN. LOCATION 15' N. Country Club Dr.

"A" P/S READING .85 TOTAL ANODES 1# — 17# — L.R. # —

REMARKS: Ran new 3/4" plastic service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Priser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	