

LOCATION 621 Clyde St.

CITY Gastonia

BETWEEN Gilmer St.

STREET &amp; Hudson Blvd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	63'	11-15-94		
MAIN TO PROP. LINE	1"	1"	7'			
PROP. LINE TO BLDG.	1"	1"	56'			

ENTERS: 625

BRANCHED INTO: 621

TAP SIZE: 3/4

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 16' S. of Caf  
Clyde St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JP

~~MAIN~~ - SIZE 3/4 C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED

DEPTH: 1 Ft. 6 In.


LOCATION

"A" P/S READING P

TOTAL ANODES 1# 17#

L.R. #

REMARKS: tested pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	OR	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY