

LOCATION 4424 Coachwood LN. CITY Gastonia

BETWEEN Knightwood STREET & Union Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>150'</u>	<u>3-4-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>110'</u>			

ENTERS: 4424 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 732' E of C of Knightwood


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 4 FT. 0 IN. LOCATION 19' S of C of Coachwood LN.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 101800

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	E	<u>Plastic</u>

ENG. DEPT. USE ONLY