

LOCATION 4505 Coachwood Ln. CITY GASTON, NC

BETWEEN Dawnwood Dr. STREET & Knightwood Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	72'	12-2-94		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	67'			

ENTERS: 4505 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 175' W. of center of

Knightwood Dr.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFSKILL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. In. LOCATION 17' S. of center of Coachwood Ln.

"A" P/S READING P TOTAL ANODES 1\* 0 17\* 0 L.R. # 512740

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	P

ENG. DEPT. USE ONLY