

LOCATION 1611 & 1613 Cole St CITY GASTONIA
BETWEEN Pear St STREET & Dead End STREET

	SIZE	TYPE	1611 LENGTH	1613	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Ø</u>	<u>70'</u>	<u>16'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>Ø</u>	<u>30'</u>	<u>8'</u>			<u>1-13-99</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Ø</u>	<u>40'</u>	<u>8'</u>			

ENTERS: 1611 BRANCHED INTO: 1613

TAP SIZE: 3/4 San PRESSURE 100 PSI _____ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY ED

MAIN-SIZE 1 1/4 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1957

DEPTH: 2 FT. 6 IN. LOCATION

"A" P/S READING 1.1 TOTAL ANODES 1# _____ 17# ✓ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY