

LOCATION 411 Collier St. CITY CAS-
BETWEEN COUNTRY CLUB RD. STREET & DEAD END. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>1.</u>	<u>2' TIEOVER</u>		<u>2-</u>	<u>10-78</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>2'</u>			

ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE: 60 PSI _____ INCHES W.C. LOCATION 149' from @ OF
COUNTRY CLUB RD.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 199
DEPTH: 3 FT. 0 IN. LOCATION W. OF COLLIER ST.

"A" P/S READING D TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY