

LOCATION 417 COLLIER ST. CITY EAST.

BETWEEN COUNTRY CLUB RD. STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>67'</u>		<u>2-</u>	<u>10-98</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>63'</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 270' FROM @ OF

COUNTRY CLUB RD.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.H.F.

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 FT. 0 IN. LOCATION U.O.F. COLLIER ST.

"A" P/S READING P. TOTAL ANODES: 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY