

LOCATION 422 COLLIER ST. CITY EAST.  
BETWEEN COUNTRY CLUB RD. STREET & DEAD END. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>TIE OVER 28'</u>			<u>2-10-78</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>28'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>28'</u>			

ENTERS: SAME BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 373' FROM @ OF  
COUNTRY CLUB RD.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1993  
DEPTH: 3 FT. 0 IN. LOCATION W. OF COLLIER ST.

"A" P/S READING P. TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<b>S</b>	
	P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY