

LOCATION 1108 Colony Ct. CITY Gastonia
BETWEEN RAVEHill Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>107'</u>	<u>4-1-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>99'</u>			


ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 31' East of Colony Ct. & 346' North of Ravenhill Ct.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BB
~~PIPE~~ SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1976

DEPTH: 3 FT. 6 IN. LOCATION 31' East of Colony Ct.

"A" P/S READING 1.2 TOTAL ANODES 1# -0- 17# -0- L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>P</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY