

LOCATION 3015 Colony Ridge Dr. CITY Castroville
BETWEEN Liberty Oak STREET & Hoffman Rd. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|---------------|----------|------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3 1/4"</u> | <u>P</u> | <u>92'</u> | <u>4-13-95</u> | | |
| MAIN TO PROP. LINE | <u>3 1/4"</u> | <u>P</u> | <u>5'</u> | | | |
| PROP. LINE TO BLDG. | <u>3 1/4"</u> | <u>P</u> | <u>87'</u> | | | |

ENTERS: 3015 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 600 P.S.I. _____ INCHES W.C. LOCATION 62' N. of center of
Liberty Oak CT


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By S. HUFFBLU

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1984

DEPTH: 3 Ft. 0 In. LOCATION 18' W. of center of Colony Ridge Dr.

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # 166870

REMARKS:



| Test Station | | |
|--|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY