

LOCATION 3021 Colony Ridge Dr. CITY Groton
BETWEEN Liberty Oak Ct STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	57'	5-5-95		
MAIN TO PROP. LINE	3/4"	P	25'			
PROP. LINE TO BLDG.	3/4"	P	32'			


ENTERS: 3021 BRANCHED INTO: 3015
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 105' W. of center of Colony Ridge Dr.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffer
MAIN SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 8 Ft. 6 In. LOCATION 61' N. of center of Liberty Oak Ct

"A" P/S READING 7 TOTAL ANODES 1* 6 17* 0 L.R. # 212506

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY