

LOCATION 3051 Colony Ridge Dr CITY GASTONIA
BETWEEN Trailwood Dr STREET & Pennsbury Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>98'</u>	<u>9-20-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>88'</u>			

ENTERS: 3051 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 42' N of C of Trailwood Dr.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 21' W of C of Colony Ridge Dr.

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY