


LOCATION 3069 Colony Ridge Dr.CITY GASTONIABETWEEN Trail-wood DR.STREET & End OF Culdesack

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>114'</u>	<u>10-19-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>8</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>106'</u>			

ENTERS: 3069BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 231' S of C of Trailwood Dr.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994DEPTH: 3 Ft. 0 In. LOCATION 19' W of C of Colony Ridge Dr."A" P/S READING Plastic N/A TOTAL ANODES 1# _____ 17# _____ L.R. # 512 773

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY