

LOCATION 609 Colorado CT CITY GASTON

BETWEEN MONTANA DR. STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>155'</u>	<u>10-8-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>110'</u>			

ENTERS: 609 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 403' W. of center of

MONTANA DR


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hultgren

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION 24' N. of center of Colorado CT

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 676376

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY