

LOCATION 213, 215 S. ColumbiaCITY GASTONIABETWEEN 2ndSTREET & Franklin

STREET

	SIZE	TYPE	115 LENGTH 113	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>(12' new)</u>	<u>Tied over</u>		
MAIN TO PROP. LINE				<u>4/17/95</u>		
PROP. LINE TO BLDG.			<u>128 65</u>			


ENTERS: 213BRANCHED INTO: 215TAP SIZE: 1/2PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION 15' W ofS ColumbiaPRESSURE TEST: @ 100 psiFor 1/4 Hrs.By M. PalkMAIN-SIZE 2"C.I. BARE STEEL COATED STEEL PLASTIC XYEAR INSTALLED 94DEPTH: 3 Ft. 0 In.LOCATION 176' N of 2nd"A" P/S READING: PTOTAL ANODES 1* 17* L.R. #

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-risers</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	