


LOCATION 301 S. Columbia St. CITY STANTONIA
 BETWEEN Columbia St. STREET & Willow St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>25'</u>	<u>12-6-00</u>	<u>28' Existing</u>	
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>8'</u>		<u>3/4 CFW Pipe</u>	
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>16'</u>			

 ENTERS 301 BRANCHED INTO 0
 TAP SIZE 3/4 PRESSURE 60 PSI INCHES W.C. LOCATION 100' w of C of Columbia St.
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL
 MAIN SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000
 DEPTH 3 FT 6 IN LOCATION 23' S of C of
 "A" P/S READING N/A Plastic TOTAL ANODES 1# 0 17# 0 L.R. #
 REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser
P/S Pipeline Lead - White Existing Main	E	Plastic