

LOCATION 306 S. Columbia St. CITY Gastonia

BETWEEN W. 2nd Ave. STREET & W. 3rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>172'</u>	<u>1-30-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>35'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>137'</u>			

ENTERS 306 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES WC LOCATION 200' S. of center of W. 2nd Ave.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992

DEPTH 3 FT 0 IN LOCATION 16' W. of center of S. Columbia St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 17249

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	