

LOCATION 308 & 312 S. Columbia

CITY Gastonia

BETWEEN 2nd

STREET & 3rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	4'	4-29-95	ties over 220' of 3/4 C/W	
MAIN TO PROP. LINE					50v. to Ext 2" P. Main	
PROP. LINE TO BLDG.						

ENTERS: 308

BRANCHED INTO: 312

TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION 16' W. of C of S. Columbia


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By P

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	1-20
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY