

LOCATION 309 S. Columbia St.CITY GastoniaBETWEEN 2ndSTREET & 7th

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$	P	2'	4-29-95	tried over 78'	$\frac{3}{4}$ C/w Serv.
MAIN TO PROP. LINE					to Ext 2"	P. Main
PROP. LINE TO BLDG.						

ENTERS: 309BRANCHED INTO: —TAP SIZE:  $\frac{1}{2}$ 

PRESSURE

P.S.I.


INCHES W.C.

LOCATION 16' W. of C of  
S. Columbia St.PRESSURE TEST: @ 100 psi For  $\frac{1}{4}$  Hrs. By JPMAIN-SIZE 2"C.I. —BARE STEEL —COATED STEEL —PLASTIC ☒YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In.

LOCATION

"A" P/S READING PTOTAL ANODES 1\* — 17\* —L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>1.30</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY