

LOCATION 314 + 314 1/2 S Columbia

CITY GASTONIA

BETWEEN 3rd

STREET & 2nd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	34' New	TIED OVER		
MAIN TO PROP. LINE			Tied over	5-1-95		
PROP. LINE TO BLDG.			85' Exist 3/4"	Orig INS 9-29-83		

ENTERS: 314

BRANCHED INTO:

TAP SIZE: 1/2

PRESSURE 60 P.S.I. _____ INCHES W.C.

LOCATION 16' West of

Columbia

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Parker

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 94

DEPTH: 3 Ft. 0 In. LOCATION 414' South of 2nd Ave


"A" P/S READING

①

TOTAL ANODES 1* _____ 17* _____

L.R. # _____

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P-riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY