

LOCATION 326 Apt 1-6 S. Columbia

CITY Gastonia

BETWEEN 2nd Ave

STREET & 3rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	Tied over	Tied over		
MAIN TO PROP. LINE			(143' 3/4 P)	5-1-95		
PROP. LINE TO BLDG.						

ENTERS: 326

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 20' East of
S Columbia


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Parker

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 208' N OF 3rd Ave

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY