

LOCATION 408<sup>S</sup> Columbia St.

CITY GASTONIA

BETWEEN Maple

STREET & 3<sup>rd</sup>

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	30'	8-14-93	30' Plastic used to tie-over	
MAIN TO PROP. LINE					41' Existing	C+W to Plastic
PROP. LINE TO BLDG.						MAIN

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 176' South of 3<sup>rd</sup> ST.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. In. LOCATION 14 West of Columbia

"A" P/S READING 1.1 TOTAL ANODES 1\* 17\* L.R. #

REMARKS: Tracerwire Not Bonded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY