

LOCATION 417 S. Columbia St. CITY GASTONIA
BETWEEN Maple St. STREET & 5th Ave. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------|-----------|----------------|--------------------|---------------------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>3'</u> | <u>8-14-93</u> | <u>Tied Over</u> | <u>55' Existing</u> |
| MAIN TO PROP. LINE | | | | | <u>3/4 PLASTIC</u> | <u>Service</u> |
| PROP. LINE TO BLDG. | | | | | <u>to new</u> | <u>P. Main</u> |

ENTERS: 417 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 600 P.S.I. _____ INCHES W.C. LOCATION 67' S of C of Maple St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL


MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 13' W of C of S. Columbia St.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

Bare Main Replacement
Program



| Test Station | | |
|--|----------|----------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>P</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY